



FIRE STOP TEST DESIGNS - ELECTRICAL

Please provide the fire stop test design numbers for the penetrations of electrical building services through fire separations (test method conforms to CAN/ULC-S115).

Attach a copy of each design that will be used to this overview sheet.

The electrical engineer or coordinating professional (for smaller projects where no electrical engineer is involved) is responsible for reviewing the designs and undertaking field review of fire stopping during construction (Schedules B-1 and B-2 and Section 2.4). Ensure the professional or representative reviews the design prior to installation.

PROJECT INFORMATION	
Project name:	Permit number:
Project address:	Date:
Designs submitted by:	
Name Company	

CONCRETE FIRE WALL PENETRATIONS - HORIZONTAL OR VERTICAL (FT RATING)				
Type of penetration	Type of wire	Product Description	FT rating	Design/Test #
Electrical cables (diameters > 25mm)				
Electical metallic tubing (EMT)/ steel conduit				

PENETRATIONS THROUGH FLOOR ASSEMBLIES				
Type of penetration	Type of wire	Product Description	FT rating	Design/Test #
Electrical cables (diameters > 25mm)				
Electical metallic tubing (EMT)/ steel conduit				

PENETRATIONS THROUGH WALL ASSEMBLIES				
Type of penetration	Type of wire	Product Description	FT rating	Design/Test #
Electrical cables (diameters > 25mm)				
Electical metallic tubing (EMT)/ steel conduit				