



# 2023 MonTerra Water Treatment Plant Summary

January 1, 2023 to Dec 31, 2023

Analysis isn't completed until the end of the calendar year

## MonTerra WTP Treated Water (Entering the Distribution System)

Parameter	Units	Winter	Summer	Average	Maximum Acceptable Concentration or Guideline <sup>1</sup>	Common Source
Aluminum	mg/L	0.0590	0.3500	0.2045	< 0.100 (O) Annual Avg	Naturally occurring and plant treatment process chemicals
Ammonia	mg/L as N	<0.05	<0.05	<0.05	No Guidelines	Naturally occurring; released agricultural or industrial wastes
Antimony	mg/L	<0.0006	<0.0006	<0.0006	0.006	Erosion of natural deposits in watershed
Arsenic	mg/L	0.00065	0.00083	0.00074	0.01	Erosion of natural deposits in watershed
Atrazine + metabolites	mg/L	<0.001	<0.001	<0.001	0.005	Leaching and/or runoff from agricultural use
Barium	mg/L	0.1100	0.0700	0.0900	1	Erosion of natural deposits in watershed
Benzene	mg/L	<0.001	<0.001	<0.001	0.005	Releases or spills from industrial use
Benzo(a)pyrene	mg/L	<0.000005	<0.000005	<0.000005	0.00004	Distribution system materials
Boron	mg/L	0.030	<0.03	<0.03	5	Naturally occurring; leaching or runoff from industrial use
Bromate	mg/L	<0.005	<0.005	<0.005	0.01	Possible contamination in hypochlorite solution
Bromoxynil	mg/L	<0.002	<0.002	<0.002	0.005	Leaching and/or runoff from agricultural use
Cadmium	mg/L	<0.00004	<0.00004	<0.00004	0.005	Erosion of natural deposits in watershed
Calcium	mg/L	47.2	32.4	39.8	No Guidelines	Erosion of natural deposits in watershed
Carbon Tetrachloride	mg/L	<0.0005	<0.0005	<0.0005	0.002	Industrial effluents and leaching from hazardous waste sites
Chloramines	mg/L	0.26	0.13	0.20	3	Formed in the presence of both chlorine and ammonia
Chloride	mg/L	29.2	20.0	24.6	≤250 (A)	Naturally occurring, dissolved salt deposits, highway salt
Chlorpyrifos	mg/L	<0.002	<0.002	<0.002	0.09	Leaching and/or runoff from agricultural use
Chromium	mg/L	0.0009	<0.0008	<0.0008	0.05	Erosion of natural deposits in watershed
Colour	TCU	<4	<4	<4	15 (A)	Erosion of natural deposits in watershed
Coliforms, <i>E. Coli</i>	MPN/100mL	Absent	Absent	Absent	0	Domestic animals, wildlife, human waste
Coliforms, Total	MPN/100mL	Absent	Absent	Absent	0	Soil, domestic animals and wildlife
Copper	mg/L	0.00210	0.00140	0.00175	2, <1(A)	Erosion of natural deposits in watershed
Cyanazine	mg/L	<0.002	<0.002	<0.002	No Guidelines	Leaching and/or runoff from agricultural use
Cyanide	mg/L	<0.003	<0.003	<0.003	0.2	Industrial and mining effluents; Release from organic compounds.
Cyanobacterial Toxins - As Microcystin, Total	mg/L	<0.00015	<0.00015	<0.00015	0.0015	Naturally occurring; released from blooms of blue-green algae
Diazinon	mg/L	<0.002	<0.002	<0.002	0.02	Run off from agricultural or other uses.
Dicamba	mg/L	<0.002	<0.002	<0.002	0.12	Leaching and/or runoff from agricultural use
1,2-Dichlorobenzene	mg/L	<0.0005	<0.0005	<0.0005	0.2	Releases or spills from industrial use
1,4-Dichlorobenzene	mg/L	<0.0005	<0.0005	<0.0005	0.005	Releases or spills from industrial use
1,2 Dichloroethane	mg/L	<0.002	<0.002	<0.002	0.005	Releases or spills from industrial use
Dichloromethane	mg/L	<0.002	<0.002	<0.002	0.05	Industrial and municipal wastewater discharges
2,4-Dichlorophenol	mg/L	<0.002	<0.002	<0.002	0.9	By-product of chlorination.
2,4 D (2,4-Dichlorophenoxy acetic acid)	mg/L	<0.002	<0.002	<0.002	0.1	Leaching and/or runoff from use as a weed controller
Diclofop-methyl	mg/L	<0.002	<0.002	<0.002	0.009	Leaching and/or runoff from use as a weed controller
Diuron	mg/L	<0.003	<0.003	<0.003	0.15	Leaching and/or runoff from use in controlling vegetation
Dimethoate	mg/L	<0.002	<0.002	<0.002	0.02	Leaching and/or runoff from agricultural use
Ethylbenzene	mg/L	<0.001	<0.001	<0.001	0.14	Emissions, effluents or spills from petroleum and chemical industries
Fluoride <sup>2</sup>	mg/L	0.140	0.120	0.130	1.5	Erosion of natural deposits in watershed
Glyphosate	mg/L	<0.020	<0.020	<0.020	0.28	Leaching and/or runoff from use as a weed controller
Haloacetic Acid, Total	mg/L	0.0170	0.0350	0.0260	0.08 (Annual Average)	By-product of chlorination
Hardness, Total	mg/L as CaCO <sub>3</sub>	231	178	205	No Guidelines	Erosion of natural deposits in watershed
Iron	mg/L	<0.02	<0.02	<0.02	≤0.300 (A)	Erosion of natural deposits in watershed
Lead	mg/L	<0.0003	<0.0003	<0.0003	0.005	Leaching from plumbing (pipes, solder, brass fittings, lead service lines)
Magnesium	mg/L	27.6	23.5	25.6	No Guidelines	Erosion of natural deposits in watershed
Malathion	mg/L	<0.002	<0.002	<0.002	0.19	Leaching and/or runoff from agricultural and other uses
Manganese	mg/L	0.00100	<0.005	<0.005	0.12, ≤0.2(A)	Erosion of natural deposits in watershed
Mercury	mg/L	<0.000001	<0.000001	<0.000001	0.001	Erosion of natural deposits in watershed
Methoxychlor	mg/L	<0.002	<0.002	<0.002	No Guidelines	Leaching and/or runoff from agricultural and other uses
Metolachlor	mg/L	<0.002	<0.002	<0.002	0.05	Leaching and/or runoff from agricultural and other uses
Metribuzin	mg/L	<0.002	<0.002	<0.002	0.08	Leaching and/or runoff from agricultural use
Monochlorobenzene	mg/L	<0.001	<0.001	<0.001	0.08	Releases or spills from industrial effluents
Nitrate	mg/L as N	0.046	<0.010	<0.010	10 (as N)	Erosion of natural deposits in watershed
Nitrite	mg/L as N	<0.005	<0.005	<0.005	1 (as N)	Erosion of natural deposits in watershed
Nitriotic Acid (NTA)	mg/L	<0.4	<0.4	<0.4	0.4	Sewage contamination
Pentachlorophenol	mg/L	<0.002	<0.002	<0.002	0.06	By-product of chlorination
pH	pH units	6.80	7.50	7.15	7-10.5 (O) 6.5-8.5 (A EPA)	Influenced by dissolved minerals in water, temp, and treatment process
Picloram	mg/L	<0.002	<0.002	<0.002	0.19	Leaching and/or runoff from agricultural and other uses
Silver	mg/L	<0.00007	<0.00007	<0.00007	No Guidelines	Naturally occurring (erosion and weathering of rocks and soils)
Simazine	mg/L	<0.002	<0.002	<0.002	0.01	Leaching and/or runoff from agricultural and other uses
Sodium	mg/L	13.3	10.6	12.0	≤200 (A)	Erosion of natural deposits in watershed
Sulphate	mg/L	50.9	44.1	47.5	≤500 (A)	Erosion of natural deposits in watershed
Sulphide	mg/L	<0.010	<0.010	<0.010	≤0.05 (A)	Reduction of sulphates by sulphate-reducing bacteria; industrial wastes
Selenium	mg/L	0.001200	0.001000	0.001100	0.05	Naturally occurring (erosion and weathering of rocks and soils)
Terbufos	mg/L	<0.0005	<0.0005	<0.0005	0.001	Leaching and/or runoff from agricultural and other uses
Tetrachloroethylene	mg/L	<0.001	<0.001	<0.001	0.01	Industrial effluents or spills
2,3,4,6-Tetrachlorophenol	mg/L	<0.002	<0.002	<0.002	0.1	By-product of chlorination; industrial effluents and use of pesticides
Toluene	mg/L	<0.002	<0.0005	<0.0005	0.06	Emissions, effluents or spills from petroleum and chemical industries
Total Dissolved Solids	mg/L	268	213	241	500 (A)	Erosion of natural deposits in watershed
Total Organic Carbon	mg/L	2.5	1.9	2.2	No Guidelines	Erosion of natural deposits in watershed
Trichloroethylene	mg/L	<0.002	<0.00030	<0.00030	0.005	Industrial effluents and spills from improper disposals
2,4,6-Trichlorophenol	mg/L	<0.002	<0.002	<0.002	0.005	By-product of chlorination; industrial effluents and spills
Trifluralin	mg/L	<0.002	<0.002	<0.002	0.045	Runoff from agricultural uses
Trihalomethanes, Total	mg/L	0.037	0.027	0.032	0.1 (Annual Average)	By-product of chlorination
Uranium	mg/L	0.000600	0.000710	0.000655	0.02	Industrial effluents or spills
Vinyl Chloride	mg/L	<0.001	<0.001	<0.001	0.002	Industrial effluents; degradation product from organic solvents in groundwater; leaching from PVC pipes
Xylenes (total)	mg/L	<0.003	<0.003	<0.003	0.09	Emissions, effluents or spills from petroleum and chemical industries
Zinc	mg/L	<0.007	0.008	0.007	≤5.000 (A)	Erosion of natural deposits in watershed/leaching from plumbing fixtures

Legend

<sup>1</sup> Maximum acceptable concentrations and guidelines as determined by Health Canada and the Alberta Environment and Parks license to operate

<sup>2</sup> Fluoride is not added at this location

(O) Operating guidance as determined by Health Canada

(A) Aesthetic Objective as determined by Health Canada

(AEPA) Alberta Environment and Protected Areas provincial guideline

< Indicates not detected above the specified parameter (less than)

mg/L = milligrams per litre, or parts per million

TCU = True Colour Units

MPN = Most Probable Number

Links

[Health Canada Guidelines for Canadian Drinking Water Quality, Summary Table \(Sept 2020\)](#)

[Health Canada Water Quality - Reports and Publications](#)

[Alberta Environment and Parks](#)